WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68593
Permit No.
Basin 071

NOTICE OF INTENT NO. 27974

1. OWNER Condrey Consultants
MAILING ADDRESS 5805 So. Grass Valley RD Winnemucca, NV.
ADDRESS AT WELL LOCATION 5805 So. Grass Valley RD Winnemucca, NV.

2. LOCATION NE ¼ SE ¼ Sec. 1 T. 35 N/S R. 37 E/W Humboldt County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	6"	
SAND - BROWN		6"	9'	
GRAYISH BROWN SANDY CLAY		9'	13'	
BROWN SANDY w/ SILT		13'	19'	
Light Brown Sithy SAND trace clay		19'	22.5'	
Light Brown SANDY Silt / few Clay		22.5'	29'	
Clayey SAND w/ gravel + silt light Brown		29'	33'	
Light Brown silty SAND w/ gravel		33'	42'	
Brown silty gravel w/ SAND		42'	47.5'	
Brown Gravely SAND w/ SILT		47.5'	54'	
Brown Gravely SAND trace clay + silt		54'	73'	
SANDY clay lens 5" + -		68'		
			73'	

Date started 3-22-96, 19
Date completed 3-22-96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 73 Feet Depth Cased 73 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8"	0	73

2" ID CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.35		SCH40	0	53

Perforations:
Type perforation .SLOT
Size perforation .020
From feet to feet
From 53 feet to 73 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 49
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 49 feet to 73 feet

9. WATER LEVEL
Static water level 64 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Drilling Inc. (Contractor)
Address 75 Lewers Creek RD Carson City NV 89704 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
Signed John S Geisel
By driller performing actual drilling on site or contractor
Date 5-24-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627