

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30420

OWNER Cliff Burns ADDRESS AT WELL LOCATION 105 HAWK ST.  
 MAILING ADDRESS 2008 3rd St. Sparks, NV 89431  
 2. LOCATION NW 1/4 NW 1/4 Sec. 7 T. 34 Q. 38 E. Pershing County  
 PERMIT NO. 09-412-10 Parcel No. BURNS ACRES Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay/SAND		0	20	20
SAND/gravel		20	30	10
fingered layers		30	100	30
SAND/gravel		40	80	20
SAND/gravel		80	90	10
SAND/gravel	XX	90	110	20

8. WELL CONSTRUCTION  
 Depth Drilled 110 Feet Depth Cased 110 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 7/8 Inches To 110 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12</u>	<u>1 8/8</u>	<u>1</u>	<u>110</u>

 Perforations:  
 Type perforation Factory Cuts  
 Size perforation 3/32  
 From 40 feet to 110 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 110 feet  
 9. WATER LEVEL  
 Static water level 65 feet below land surface  
 Artesian flow NO G.P.M. N/A P.S.I.  
 Water temperature 60.1 °F Quality Good

Date started 3/11, 1996  
 Date completed 3/11, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>N/A</u>	<u>2 hr</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FRED ANDERSON Contractor  
 Address 10700 Grass Valley Rd Winnemucca, NV 89445 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board: 0021467  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1375  
 Signed [Signature] By driller performing final printing on site or contractor  
 Date 4/26/96