

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17858

1. OWNER Las Vegas Valley Water District ADDRESS AT WELL LOCATION Constantinople Ave. NE Corner of Buffalo Dr.
 MAILING ADDRESS 1001 Valley View Las Vegas NV 89153

2. LOCATION NW 1/4 NW 1/4 Sec. 10 T 20 N 60 E Clark County
 PERMIT NO. R012 138101004
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Not logged		0	70	
Clay - gravel		70	190	
Brullets - Clay		190	215	
Gravel + Clay		215	348	
Sand gravel + clay	355	348	520	
Gravel + sand		520	599	
Hard Rock + sand		599	635	
Coarse gravel + sand		635	672	
Coarse gravel, sand + clay		672	686	
Boulders		686	714	
Coarse gravel + sand		714	767	

8. WELL CONSTRUCTION
 Depth Drilled 767 Feet Depth Cased 759 Feet

HOLE DIAMETER (BIT SIZE)
 From To
26 Inches 70 Feet 395 Feet
22 Inches 595 Feet 767 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30	97	3.75	0	70
16	49.9	10 gauge double wall	0	767

Perforations:
 Type perforation mill out
 Size perforation 1.25 x 2" (16 slots ft)
 From 308 feet to 596 feet
 From 620 feet to 740 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 300' Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 10-31-99 10/31/96 19____
 Date completed 10-15-97 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>1800</u>	<u>190</u>	<u>16.7 Hrs</u>

9. WATER LEVEL
 Static water level 316 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Weber Group Inc. Contractor
 Address 116825 Weber Dr. Chandler Az 85226-4112 Contractor
 Nevada contractor's license number 035639 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2024 TL

Signed John Hammond
 By driller performing actual drilling on site or contractor
 Date May 30, 1997