

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 68629  
 Permit No. 56344T  
 Basin 21a

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15858

1. OWNER LAS VEGAS VALLEY WATER DIST ADDRESS AT WELL LOCATION WELL # 79  
 MAILING ADDRESS 1001 S. VALLEY VIEW L.V.V.W.D. WATER FIELD  
LAS VEGAS NV 89153 ALTA + VALLEY VIEW - NE CORNER

2. LOCATION SE 1/4 SW 1/4 Sec. 29 T. 20 N. R. 60 E. CLARK County

PERMIT NO. 56344-T 13929401001 Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
REHABILITATION INCLUDED:				
WIRE BRUSHING 300' TO 1240'				
SUPER CLORINATION OF PERFORATED ZONES - CHLORINE SWABBED IN EACH ZONE				
AIR LIFT DEVELOPMENT OF PERFORATED ZONES				
BACKED SANDS FROM BOTTOM TO 1259'				
TEST PUMPER WELL				

8. WELL CONSTRUCTION  
 Depth Drilled 1280 Feet Depth Cased 1260 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20'		3/8"	0	1260

Perforations:  
 Type perforation WIRE WRAPPED SCREEN  
 Size perforation  
 From 300 feet to 350 feet  
 From 630 feet to 690 feet  
 From 850 feet to 910 feet  
 From 1140 feet to 1240 feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 80 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 8-12 1997  
 Date completed 8-89 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>2500</u>	<u>113</u>	<u>22</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name B. L. WEISS GROVE Contractor  
 Address 16825 S. WEISS DRIVE  
CHANDLER AZ 85226 Contractor

Nevada contractor's license number 035639  
 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2023

Signed Kermit W. Hoover  
 By driller performing actual drilling on site or contractor

Date 8-11-97