WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68643
Permit No.
Basin 162

NOTICE OF INTENT NO. 15549

1. OWNER Jane Riddle
MAILING ADDRESS 9801 S. Vickie Ann
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
9801 S. Vickie Ann

2. LOCATION SW 1/4 SW 1/4 Sec. 36 T 21S N/S R E 53 E Ney County
PERMIT NO. Issued by Water Resources
44-771-37 Parcel No.
Calvada Valley Unit 14 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	2	2
Grey Calache		2	12	10
White Clay		12	22	10
Grey Calache		22	35	13
Clay		35	45	10
Grey Calache		45	59	14
Grey Clay		59	79	20
Brown Clay		79	83	4
Brown Clay		83	100	17
Light Brown Clay		100	128	28
Brown Clay		128	140	12
Gravel		140	150	10
Brown Calache		150	175	25
Clay	180ft.	175	190	15
Brown Calache and Gravel	x	190	215	25
Grey Calache and Gravel	x	215	226	11

RECEIVED OCT 30 1997 DIVISION OF WATER RESOURCES LAS VEGAS

Date started 7/11/97 , 19__
Date completed 7/12/97 , 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	N/A	.50

8. WELL CONSTRUCTION
Depth Drilled 226 Feet Depth Cased 226 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 3/4	Inches	0 Feet	226 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	226

Perforations:
Type perforation Saw Cut
Size perforation .188
From 190 feet to 226 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 226 feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, ~~the on-site driller~~ 2025
Signed [signature] By driller performing actual drilling on-site or contractor
Date 7-18-97