

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33900

1. OWNER GEOFFREY & PATRICIA ALDEN ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2607 Powder Drive \_\_\_\_\_  
Reno, Nevada 89506 \_\_\_\_\_  
 2. LOCATION S 34 E 1/4 Sec. 14 13 T. 22N N/S R. 19 E. Washoe County  
 PERMIT NO. 079-480-764-02 Antelope Valley Rock Est. #2665 Subdivision Name pat. 5  
 Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown sandy clay		1	3	2
Brown sand		3	4	1
Brown sandy clay		4	31	27
Decomposed granite sands		31	32	1
Brown sandy clay		32	47	15
Weathered granite		47	80	33
Gray granite		80	141	61
Broken fracture granite		141	179	38
Gray granite		179	181	2

8. WELL CONSTRUCTION  
 Depth Drilled 181 Feet Depth Cased 181 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 181 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	181

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 136 feet to 176 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50 feet  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 181 feet

Date started 7-2-97, 19\_\_\_\_  
 Date completed 7-3-97, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		

9. WATER LEVEL  
 Static water level 75 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 30 P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number issued by the State Contractor's Board 0022549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date July 7, 1997

RECEIVED  
 97 JUL 14 AM 11:45  
 STATE ENGINEERS OFFICE