WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

26-BEO

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68649
Permit No.
Basin 93

NOTICE OF INTENT NO. 33899

1. OWNER Bob & Tammye Cain
MAILING ADDRESS 3056 Scarborough
Sparks, Nevada 89434

ADDRESS AT WELL LOCATION
1357 Antelope VAlley Road
Reno, Nevada 89506

2. LOCATION NW ¼ NW ¼ Sec 26 T 22N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 079-450-~~2172~~ (Parcel No.) Antelope Valley (Subdivision Name) Rock Est #272 pg 53

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	4	3
Gray fine sand		4	32	28
Brown sandy clay		32	68	36
Soft zone, brown sand		68	71	3
Brown soft sandy clay		71	101	30
Soft zone	X	101	105	4
Brown sandy clay		105	124	19
Decomposed granite sands medium with streaks of clay	X	124	143	19
Decomposed sands		143	145	2

97 JUL 14 AM 11:45
STATE ENGINEER'S OFFICE

Date started 7-7-97, 19
Date completed 7-8-97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		

8. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	145 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	145

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 145 feet

9. WATER LEVEL
Static water level 76 feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date July 10, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627