WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68663
Permit No.
Basin 04

NOTICE OF INTENT NO. 32522

1. OWNER ELKO CITY
MAILING ADDRESS 1751 COLLEGE AVE
ELKO, NV 89801

ADDRESS AT WELL LOCATION
CITY OF ELKO

2. LOCATION SW ¼ NE ¼ Sec. 30 T 35 N/S R 56 E ELKO County
PERMIT NO. 61712 / W-449 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL & CLAY		0	25	25
CLAYS		25	45	20
ROCK - SMALL AMOUNT CLAY		45	55	10
CLAY - SOME ROCK		55	70	15
CLAY		70	90	20
CLAY - GRAVEL		90	160	70
ROCK - SMALL AMOUNT CLAY		160	200	40
MOSTLY CLAY - SOME GRAVEL		200	230	30
CLAY - GRAVEL		230	270	40
MOSTLY GRAVEL - SOME CLAY		270	490	220
MOSTLY CLAY - SOME GRAVEL		490	570	80
ROCK		570	610	40

RECEIVED FEB 12 1996 ENGINEERING OFFICE

Date started JANUARY 31, 19 96
Date completed FEBRUARY 2, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 610 Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9-7/8	Inches	0	Feet	10	Feet
7-7/8	Inches	10	Feet	610	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
N/A				

Perforations:
Type perforation N/A
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

BENTONITE
[redacted] ☒ Yes ☐ No
From 50 feet to 610 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1880

Signed DAVID R. DORIOT (By driller performing actual drilling on site or contractor)
Date FEBRUARY 2, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627