WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68672
Permit No.
Basin 87

NOTICE OF INTENT NO. 31548

1. OWNER R. S. PARSONS
MAILING ADDRESS 3555 LAMAY LANE
RENO, NV 89511

ADDRESS AT WELL LOCATION SAME

2. LOCATION NW SW/4 SW ¼ Sec. 12 T. 18 N/S R. 19 E WASHOE County
PERMIT NO. 005608 (Issued by Water Resources) 040 691 07 (Parcel No.) FAIRVIEW FARMS (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CONSTRUCTION FILL		0	10	10
GRY-BLK SAND, GRVL, COBBLES		10	60	50
BRKN BLK VOL		60	67	7
BRWN, SNDY GRVL		67	85	18
BRWN CLAY		85	105	20
GRY CLAY W V MINOR SAND		105	130	25
BRWN CLAYEY SAND		130	165	35
HARD, WT VOL ASH		165	187	22
GRY CLAY TO GRN-GRY 230-235		187	235	48
DARK BLUE/GRY CLAY		235	270	35
DARK GRY CLAY		270	280	10
BLUE/GRN VOL, SOME GRVL		280	300	20
DARK GRY CLAY		300	330	30
ANDACITE MINOR RD CLAY		330	365	35
ANDACITE		365	390	25

Date started 6/9, 1997
Date completed 6/18, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
70	—	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 390 Feet Depth Cased 390 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14	Inches	0 Feet	150 Feet
13 3/8	Inches	150 Feet	390 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	17	.188	+3	390

Perforations:
Type perforation SAW CUT (DOUBLE)
Size perforation 3X 3/16
From 190 feet to 390 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 140
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140 feet to 390 feet

9. WATER LEVEL
Static water level 138 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature 68 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NEVADA DRILLING, INC (Contractor)
Address 75 LEWERS CRK RD (Contractor)
WASHOE VALLEY
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Joe Reisek (By driller performing actual drilling on site or contractor)
Date 7/7/97

RECEIVED 97 JUL 15 AM 8:48 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627