

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13017

1. OWNER 680 FOM ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 8070 Arroyo St #7 CITYVIEW S LAS VEGAS NV  
LV NV 89119  
 2. LOCATION SW 1/4 SW 1/4 Sec. 07 T. 20 N. R. 62 E. Clark County  
 PERMIT NO. MO-2469 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>CLAY</u>		<u>0</u>	<u>22</u>	
<u>CLAYSTONE</u>		<u>22</u>	<u>25</u>	
<u>CLAY</u>		<u>25</u>	<u>51</u>	
<u>CLAYSTONE</u>		<u>51</u>	<u>56</u>	
<u>CLAY w/sand</u>				
<u>FILL</u>		<u>56</u>	<u>80</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 80 Feet Depth Cased 80 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Inches To 80 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.5</u>	<u>PVC</u>	<u>0.440</u>	<u>0</u>	<u>60</u>

 Perforations:  
 Type perforation 5/16" HO SCREEN  
 Size perforation 2.00  
 From 60 feet to 80 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 58 feet to 80 feet  
 9. WATER LEVEL  
 Static water level 76 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

RECEIVED  
 NOV 03 1994  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 7-18 19 94  
 Date completed 7-18 19 94

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WESLEY ENVIROMENTAL Contractor  
 Address 4801 S. UTLEY VIEW #21 Contractor  
LV NV 89103  
 Nevada contractor's license number 0025139 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1910  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 10-13-94