WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68684
Permit No.
Basin 71

NOTICE OF INTENT NO. 36922

1. OWNER Bret Tompkins
MAILING ADDRESS 9200 S. Beechcraft
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION
4850 Cowboy Way

2. LOCATION SW 1/4 SE 1/4 Sec. 7 T 35N N/S R 38E E Humboldt County
PERMIT NO. _____ Issued by Water Resources | 10-484-11 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Cobbles		0	75	75
Boulders		75	215	140
Lost circulation		215	222	7
Fractured rock		222	285	63

RECEIVED 97 JUL 18 AM 10:10 STATE ENGINEER'S OFFICE

Date started 6/14/97, 19__
Date completed 6/18/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 285 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 7/8	Inches	0	Feet	220	Feet
6 1/8	Inches	220	Feet	285	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	220
5 9/16		.188	210	280

Perforations:
Type perforation Single row mill slot
Size perforation 1/8 x 3
From 220 feet to 280 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 220
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 200 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 W. Winnemucca Blvd
Contractor
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019

Signed Terri A. Tompkins
By driller performing actual drilling on-site or contractor

Date 7-16-97