WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 68695
Permit No.
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. MW-2B

1. OWNER Nellis Air Force Base
MAILING ADDRESS FWC/EV, Bldg 899
Nellis AFB, NV 89191-5000

ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SE ¼ Sec 16 T 20 S R 62 E Clark County
PERMIT NO. MO-2208 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☐ Monitoring Test ☒ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy SILT		0	13	13
Silty GRAVEL		13	19	6
Silty SAND		19	23	4
SAND, fine		23	27	4
Caliche		27	29	2
SAND, fine		29	33	4
Sandy SILT		33	38	5
caliche		38	43	5
SAND, fine		43	45	2
caliche		45	52.5	7.5
sandy SILT		52.5	57.5	5
caliche		57.5	59	1.5
sandy SILT		59	65	6
clayey SILT	75'	65	70	5
silty CLAY		70	92.5	22.5
clayey SILT		92.5	98	5.5
~~sandy~~ SILT		98	103	5
sandy CLAY		103	108	5
clayey SAND		108	118	10
SAND, fine		118	137	19
clayey SAND		137	149	12
SAND, fine		149	153	4
sandy CLAY		153	162	9
SAND, fine to med		162	168	6

Date started November 8, 1992
Date completed November 9, 1992

7. N/A WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
JAN 25 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter ..... inches Total depth 167 feet
OD = 2.5 inches
ID = 2.32 inches
Casing record PVC
Weight per foot — Thickness Sch 80

OD Diameter	From	To
2.5 inches	0 feet	167 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Portland Cement Grout
Depth of seal 0 to 125 feet
~~Gravel~~ SAND packed: Yes ☒ No ☐
~~Gravel~~ SAND packed from 132 feet to 168 feet

Perforations:
Type perforation Sch 80 PVC
Size perforation 0.02 inch
From 137 feet to 167 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 75 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HF-Drilling Inc (Contractor)
Address 1456 B South Manhattan, Fullerton Ca (Contractor)
Nevada contractor's license number issued by the State Contractor's Board Gov't land
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1747
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 1/6/93

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627