

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 68706
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15853

1. OWNER TEYACO ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3283 N LAS VEGAS 3282 N CHEYENNE LAS VEGAS N.V.
LAS VEGAS NEVADA
 2. LOCATION NE 1/4 NW 1/4 Sec. 18 T. 20 S. R. 62 E. C1215 County
 PERMIT NO. W-2636-B Parcel No. 140-18-1-97 Subdivision Name _____
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt / gravel		0	0.5	0.5
Tan silty sand		0.5	8.0	7.5
Tan silty clay		8.0	19.0	11.0
Brown Tan silty sandy clay / clayey sand	✓	11.0	70.0	69.0
SWL ≈ 50'				

8. WELL CONSTRUCTION
 Depth Drilled 70 Feet Depth Cased 40-70 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
8 Inches 0 Feet 70 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>9"</u>			<u>0</u>	<u>40</u>

 Perforations:
 Type perforation slotted .020
 Size perforation .020
 From 40 feet to 70 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 0-3.5' Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured Bentonite pellets
 Gravel Packed: Yes No 35-37
 From 37 feet to 70 feet

Date started 4-22- 1996
 Date completed 4-22- 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 4 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name John Newley Contractor
 Address Vede Drilling Co.
 Nevada contractor's license number issued by the State Contractor's Board 0041809
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1765T/M1
 Signed John Newley 1765T-M1
 By driller performing actual drilling on site or contractor
 Date 5-20-96