WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68713
Permit No.
Basin 13713

NOTICE OF INTENT NO.

1. OWNER KENNETH & BOBBIE BERL
MAILING ADDRESS HC 60 BOX 53702 HWY 376 ROUND MOUNTAIN NEVADA ~~[illegible]~~ 89045
ADDRESS AT WELL LOCATION HC 60 BOX 53702 HWY 376 - BEHIND JUMANG JACK MOTEL ROUND MTN NEV 89045

2. LOCATION SW ¼ NW ¼ Sec. 29 T. 11 N/S R. 43 E. NYE County
PERMIT NO. (Issued by Water Resources) Parcel No. 10-361-05 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ALUVIN		0	5	5
COARSE SAND		5	11	6
BROWN CLY		11	13	2
LARGE GRAVEL		13	20	7
TAN CLY		20	22	2
LARGE GRAVEL		22	27	5
YELLOW CLY		27	35	8
SMALL GRAVEL		35	42	7
LARGE GRAVEL		42	48	6
BROWN CLY		48	62	14
SMALL GRAVEL		62	65	3
WHITE CLY		65	68	3
BOLDERS & LARGE GRAVEL	X	68	90	22
WHITE CLY		90	110	20
GRAVEL	X	110	125	15

RECEIVED 97 JUL 8 AM 11:05 STATE ENGINEER'S OFFICE

Date started 7-7-97, 19 97
Date completed 7-7-97, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100	0	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased 125 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	50 Feet
8 3/4 Inches		50 Feet	125 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	125

Perforations:
Type perforation MILLED
Size perforation 3 X 1/8
From 70 feet to 90 feet
From 115 feet to 125 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level FLOWING feet below land surface
Artesian flow YES G.P.M. 2 P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WOYTEK DRILLING CO INC (Contractor)
Address 2220 STOWE DR (Contractor)
RENO NEVADA 89511
Nevada contractor's license number issued by the State Contractor's Board 0024521A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed Thomas on Harris (By driller performing actual drilling on site or contractor)
Date 7-7-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627