

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14417

1. OWNER Broadbent & Assoc ADDRESS AT WELL LOCATION Wendys
 MAILING ADDRESS 833 N.W. Hwy STE 4 3251 N Las Vegas Blvd
BC No. 89005
 2. LOCATION NW 1/4 NW 1/4 Sec. 18 T 20 N 62 E Clark County
 PERMIT NO. MO-2538 140-18-101-004 Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE LW-12
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Asphalt</u>		<u>0</u>	<u>6"</u>	<u>6"</u>
<u>silty clay</u>		<u>6"</u>	<u>10'</u>	<u>9.6"</u>
<u>sand silt</u>		<u>10'</u>	<u>12'</u>	<u>2'</u>
<u>silty clay</u>		<u>12'</u>	<u>60'</u>	<u>48</u>
				<u>48.4"</u>

8. WELL CONSTRUCTION
 Depth Drilled 60' Feet Depth Cased 60' Feet
 HOLE DIAMETER (BIT SIZE)
 From 8" To 60'
 Inches _____ Feet _____
 Inches _____ Feet _____
 Inches _____ Feet _____
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.64</u>	<u>0.218</u>	<u>0'</u>	<u>60'</u>

Perforations:
 Type perforation Factory slot
 Size perforation 0.020
 From 45' feet to 60' feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 0' to 36'/36-40' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 40' feet to 60' feet

RECEIVED
 APR 21 1995
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started March 22, 1995
 Date completed _____, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Thomas R. High Contractor
 Address 4670 So. Polaris Ave
L.V. NV 89103 Contractor
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
 Signed Thomas R. High
 By driller performing actual drilling on site or contractor
 Date April 17, 1995