WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68719
Permit No.
Basin 212

NOTICE OF INTENT NO.

1. OWNER Scarborough Properties
MAILING ADDRESS 5600 Spring Mtn RD #106 L.V. NV. 89102
ADDRESS AT WELL LOCATION SEC Cheyenne Ave & Las Vegas Blvd S. L.V. NV.

2. LOCATION NE ¼ NW ¼ Sec. 18 T. 20 N/S R. 62 E. Clark County
PERMIT NO. MO-2510 Issued by Water Resources
Parcel No. 260-010-048 & 046
Subdivision Name N/A

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay Brn		0	10	10'
Sandy Clay w/Gravel		10	30	20'
Sandy Clay Lht Brn		30	40	10'
Sand Brn		40	43	3'
Clayey Sand		43	45	2'
Sand Brown	☑	45	55	10'
Clay w/Sand		55	70	15'

RECEIVED
APR 24 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 11-7-, 1994
Date completed 11-8-, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 70' Feet Depth Cased 70' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 1/4 Inches		0 Feet	70 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	—	—	0	70

Perforations:
Type perforation Slot
Size perforation 0-020
From 45 feet to 70 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 35
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 35 feet to 70 feet

9. WATER LEVEL
Static water level 47 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature 72 °F Quality TUZ BID

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Scott Davis Contractor
Address 3711 Regulus Dr Contractor
L.V. NV.
Nevada contractor's license number issued by the State Contractor's Board —
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1930
Signed By driller performing actual drilling on site or contractor
Date 11-20-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627