



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18222

1. OWNER SEA COR ADDRESS AT WELL LOCATION 15 N. LAMB
 MAILING ADDRESS 3021 S. VANCE VIEW LV NV 89103
 2. LOCATION SE 1/4 SE 1/4 Sec. 31 T 20 N 0 R 62 E CLARK County
 PERMIT NO. MO-2473 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other TUBEN

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>CLAY</u>		<u>0</u>	<u>15</u>	
<u>CLAY</u>		<u>15</u>	<u>18</u>	
<u>CLAY</u>		<u>18</u>	<u>30</u>	

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 30 Feet
 HOLE DIAMETER (BIT SIZE)
 From 7 Inches To 30 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1.5</u>	<u>PVC</u>	<u>SC40</u>	<u>0</u>	<u>28</u>

Perforations:
 Type perforation Slotted Screen
 Size perforation 20
 From 28 feet to 30 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 25
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 26 feet to 28 feet

9. WATER LEVEL
 Static water level 17 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WEBER ENVIRONMENTAL Contractor
 Address 4301 S. VANCE VIEW Contractor
LV NV 89103
 Nevada contractor's license number issued by the State Contractor's Board 0035139
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 171847
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 10-21-94

Date started 7-23, 1994
 Date completed 7-23, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED
 NOV 01 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV