



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14414  
 ADDRESS AT WELL LOCATION 5525 W. Charleston

1. OWNER Red Rock Mini mart ADDRESS AT WELL LOCATION 5525 W. Charleston  
 MAILING ADDRESS 5525 W. Charleston LV NV  
 2. LOCATION NW 1/4 NE 1/4 Sec. 01 T. 21 N. R. 60 E Clark County  
 PERMIT NO. MO-2394 B 163-01-103-003 Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY SAND		0	5	5
CEMENTED SAND/GRAV.		5	7	2
SILTY SAND		7	24	14
GRAVELLY SAND		24	26	2
SILTY SAND		26	38	12
CEMENTED GRAVEL		38	40	2
CAUCHE		40	42	2
SILTY CLAY		42	53	11
CAUCHE		53	56	3
SILTY CLAY		56	65	9

8. WELL CONSTRUCTION  
 Depth Drilled 65 Feet Depth Cased 65 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10' Inches To 0' Feet 65 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>1.9</u>	<u>0.237</u>	<u>0'</u>	<u>65</u>

Perforations:  
 Type perforation Factory slot  
 Size perforation 0.020  
 From 40 feet to 65 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-29' / 29' - 36' BENTONITE  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 36 feet to 65 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Thomas R. High Contractor  
 Address 4670 So. Polaris Ave  
L.V. NV. 89103 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869  
 Signed Thomas R. High  
 By driller performing actual drilling on site or contractor  
 Date April 17, 1995

Date started MARCH 9, 1995  
 Date completed MARCH 9, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			