WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68731
Permit No.
Basin 212

NOTICE OF INTENT NO. 12142

1. OWNER LAS VEGAS VALLEY WATER DIST
MAILING ADDRESS 3700 W. CHARLESTON
LAS VEGAS, NV 89153
ADDRESS AT WELL LOCATION BONANZA HIGH SCHOOL, 6665 WEST DEL RAY AVE
LAS VEGAS, NV

2. LOCATION SE ¼ NW ¼ Sec. 2 T. 21 N/S R. 60 E. CLARK County
PERMIT NO. M0-2379 Issued by Water Resources
310-420-005 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL		0	1	1
GRAVELLY SAND		1	7	6
CEMENTED SAND/GRAVEL		7	10	3
SILTY SAND		10	16	6
SANDY GRAVEL		16	18	2
SANDY CLAY		18	22.5	4.5
WELL GRADED GRAVEL		22.5	28	5.5
SANDY GRAVEL		28	29.5	1.5
GRAVELLY SAND		29.5	31	1.5
SANDY CLAY		31	33	2
CLAYEY SAND		33	37	4
SILTY SAND w/ GRAVEL		37	38	1
SANDY CLAY		38	40	2
SILTY SAND		40	50	10
SANDY GRAVEL		50	53	3
SILTY SAND		53	57	4
SANDY GRAVEL		57	60	3
WELL GRADED SAND		60	62	2
SANDY GRAVEL		62	67	5
SILTY SAND		67	69	2
GRAVELLY SAND		69	77	8
SANDY GRAVEL		77	80	3
SILTY SAND		80	83	3
SANDY GRAVEL		83	84	1
GRAVELLY SAND		84	90	6

Date started JAN 4, 1994
Date completed JAN 4, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
JAN 14 1994
Water Resources
Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 90 Feet Depth Cased 84 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	85 Feet
5 Inches		85 Feet	90 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
3.5	1.4	0.216	0	84

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 69 feet to 79 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-63'/63-66' BENT.
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 66 feet to 84 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON
Contractor
Address 4670 SOUTH POLARIS
Contractor
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed
By driller performing actual drilling on site or contractor
Date JAN 13, 1994

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627