

OFFICE USE ONLY
 Log No. 68733
 Permit No. _____
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24918

1. OWNER TRACY Caldwell ADDRESS AT WELL LOCATION Picket Valley
 MAILING ADDRESS Box 3603 WENDOVER, NV 89833 UNIT 2 Bldg 7 Lot 8
 2. LOCATION SW 1/4 SW 1/4 Sec. 12 T. 37 N/S R. 69 E 3/4 County _____
 PERMIT NO. _____ Issued by Water Resources Parcel No. 626 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	1	
SANDY CLAY		1	18	
Gravel		18	27	
CLAY		27	48	
Gravel		48	52	
SOFT CLAY		52	107	
CLAY & Thin GRAV		107	170	

Goolds 186500412 set
 at 147' by TSC

8. WELL CONSTRUCTION
 Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 170 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>12</u>	<u>168</u>

Perforations:
 Type perforation Factory Slot & Torch
 Size perforation 1/8 x 3'
 From _____ feet to _____ feet
 From 130 feet to 150 feet Torch
 From 150 feet to 170 feet Factory
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 52
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 52 feet to 170 feet

9. WATER LEVEL
 Static water level 63 AG-1 feet below land surface
 Artesian flow 0 G.P.M. 0 P.S.I.
 Water temperature _____ °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name R.D. Reynolds Contractor
 Address Wells, NV Contractor
 Nevada contractor's license number issued by the State Contractor's Board 014410
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1390
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8-29-96

Date started _____, 1996
 Date completed _____, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>20</u>	<u>40</u>	<u>3 hrs</u>

RECEIVED
 SEP 20 AM 11:4
 WATER ENGINEERS OFFICE