


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 68743  
 Permit No. \_\_\_\_\_  
 Basin 101



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18458

1. OWNER KOPAS KONSTRUCTION ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 5105 SANDALWOOD 1295 VENTURACCI LANE  
FALLON, NV 89406  
 2. LOCATION SE 1/4 SE 1/4 Sec. 24 T 19 N/S R 28 E CHURCHILL County  
 PERMIT NO. 0831289 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN SAND		0	14	14
BROWN CLAY		14	20	6
GREY SAND		20	30	10
BLACK SILT		30	50	20
GREY SAND		50	65	15
GREY CLAY		65	70	5
BROWN SILT		70	75	5
BROWN CLAY		75	78	3
BROWN SAND	X	78	89	11

8. WELL CONSTRUCTION  
 Depth Drilled 89 Feet Depth Cased 89 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 3/4 inches 0 Feet 50 Feet  
6 1/8 inches 50 Feet 89 Feet  
 \_\_\_\_\_ inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	89

Perforations:  
 Type perforation MACHINE SLOT  
 Size perforation .080  
 From 82 feet to 85 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 9.4 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Welsco Drilling Corp. Contractor  
 Address 305 E. WILLIAMS AVE. P. O. BOX 888 Contractor  
FALLON, NV 89407  
 Nevada contractor's license number issued by the State Contractor's Board 11752  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996  
 Signed [Signature] By driller performing actual drilling on-site or contractor  
 Date 6-5-97

Date started 6/2/97, 19\_\_\_\_  
 Date completed 6/5/97, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>1 hr.</u>