WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. L8748
Permit No.
Basin 105

NOTICE OF INTENT NO. 32636

1. OWNER Cal Sanders
MAILING ADDRESS 1181 Quarry Ln. Suite 100 Pleasanton, Ca. 94566
ADDRESS AT WELL LOCATION Not Assigned Yet off Hwy 88 Gardnerville

2. LOCATION NW ¼ NW ¼ Sec. 6 T. 12 N/S R. 19 E. Douglas County
PERMIT NO. Issued by Water Resources
Parcel No. 19-100-29
Subdivision Name 1220-06-001-005

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
Brown Clay with Surface Water		3	18	15
Coarse Gravels		18	75	57
¾ arrigate Rock		75	110	35
Coarse Sands and River Rock	XX	110	145	35
¼ Gravels	XX	145	156	11

RECEIVED 97 MAY 23 PM 1:01 STATE ENGINEER'S OFFICE

Date started 5-19, 1997
Date completed 5-21, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50+	45	5 HRS

8. WELL CONSTRUCTION
Depth Drilled 156' Feet Depth Cased 156' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/4 Inches		0 Feet	156 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	156

Perforations:
Type perforation Mill Slot
Size perforation 3x3/32
From 116 feet to 156 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 100 feet to 156 feet

9. WATER LEVEL
Static water level 3 feet below land surface
Artesian flow G.P.M. 50+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling Contractor
Address 20 Kit Kat DR. Contractor
Carson City NV. 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1205
Signed Michael L Beck
By driller performing actual drilling on site or contractor
Date 5-21-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627