WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 63751
Permit No.
Basin 105

NOTICE OF INTENT NO. 32625

1. OWNER Charles Jones
MAILING ADDRESS 2174 Calle Hermosa Gardnerville NV. 89423
ADDRESS AT WELL LOCATION 1504 Pahlum Gardnerville NV. 89423

2. LOCATION SE ¼ SE ¼ Sec. 32 T. 13 N/S R. 21 E. Douglas County
PERMIT NO. Issued by Water Resources | Parcel No. 23-180-55 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay	-	0	12	12
Course DG Sands		12	45	33
Brown Clay Zone (Edi)		45	95	50
Soft Zone obsidion Sands	x	95	120	35
Blue Clay		120	155	35
Soft Zone Sands and Gravels	XXX	155	190	35
TD 190'				
GPM 18-20'				

Date started 7-28, 1997
Date completed 7-31, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	70	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	120 Feet
7⅞ Inches		120 Feet	190 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.34	.188	0	120
6⅝	13.03	.188	110	190

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 80 feet to 120 feet
From 150 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 120' feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. 18-20 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat DR. Carson City NV. 89706 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7-31-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627