

OFFICE USE ONLY  
 Log No. 68760  
 Permit No. \_\_\_\_\_  
 Basin 16a

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15562

1. OWNER Matthew Held ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3681 Sagebrush 3681 SAGEBRUSH  
Pahrump, NV 89048

2. LOCATION NE 1/4 SW 1/4 Sec. 31 T 20 N/S R 54E E Nye County  
 PERMIT NO. \_\_\_\_\_ 41-243-21 CALVADA VALLEY  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY BROWN LOAM		0	5	5
BROWN CLAY		5	45	40
CALACHE		45	50	5
BROWN CLAY		50	65	15
CLAY		65	75	10
CALACHE	X	75	85	10
BROWN CALACHE	X	85	95	10
LIGHT CLAY	X	95	115	20
CLAY AND GRAVEL	X	115	135	20
CLAY	X	135	150	15

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 7/8 Inches 0 Feet 150 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	150

Perforations:  
 Type perforation SAW CUT  
 Size perforation .188  
 From 110 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 150 feet

9. WATER LEVEL  
 Static water level 75 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Strickland Construction Co., Inc. Contractor  
 Address 2301 Winery Road, Suite 2 Contractor  
Pahrump, NV 89048  
 Nevada contractor's license number issued by the State Contractor's Board 40277  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 10.21.97

Date started 10/8/97 19\_\_  
 Date completed 10/8/97 19\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>.50</u>	<u>N/A</u>	<u>.50</u>

RECEIVED  
 OCT 30 1997  
 DIVISION OF WATER RESOURCES  
 LAS VEGAS OFFICE