WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68761
Permit No.
Basin 162

NOTICE OF INTENT NO. 15565

1. OWNER Lupi and Mike Lawler
MAILING ADDRESS 1951 E. Santovito
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
1951 E. Santovito

2. LOCATION NE 1/4 SE 1/4 Sec. 14 T 21 N/S R 53E E Nye County
PERMIT NO. _____ Issued by Water Resources
44-752-10 Parcel No.
Mesa Ostie Estate Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GREY CLAY		0	4	4
LIGHT GREY CLAY		4	9	5
GREY CLAY		9	17	8
GREY CLAY		17	34	17
GREY CALACHE		34	42	8
BROWN CALACHE		42	52	10
LIGHT BROWN CLAY		52	60	8
BROWN CALACHE	X	60	72	12
LIGHT GREY CALACHE	X	72	80	8
BROWN CLAY	X	80	94	14
BROWN CLAY/ GRAVEL	X	94	105	11
GREY CALACHE	X	105	112	7
GREY CALACHE	X	112	128	16
LIGHT GREY CALACHE	X	128	140	12

RECEIVED
OCT 30 1997
DOWN
LAS VEGAS OFFICE

Date started 10/5/97, 19__
Date completed 10/5/97, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
.5	na	.50

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 7/8	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
Type perforation SAW CUT
Size perforation .188
From 110 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed Larry Strickland By driller performing actual drilling on site or contractor
Date 10-21-97