WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68770
Permit No.
Basin 105

NOTICE OF INTENT NO. 36758

1. OWNER John DeCarlo Construction
MAILING ADDRESS P.O. Box 158 Gardnerville NV 89410
ADDRESS AT WELL LOCATION 1465 Calle Pequeno Gardnerville, NV 89410

2. LOCATION NE ¼ SW ¼ Sec. 32 T. 13 N/S R. 21 E. Douglas County
PERMIT NO. ____ Issued by Water Resources | 23-180-12 Parcel No. | Fish Springs Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Rock & Soil | | 0 | 7 | 7 |
| Boulders Sand Gravel | | 7 | 37 | 30 |
| Sandy Clay | | 37 | 69 | 32 |
| Sand & Gravel | | 69 | 113 | 44 |
| Red Boulders | | 113 | 115 | 2 |
| Sand & Gravel | ✓ | 115 | 142 | 27 |
| Boulders | ✓ | 142 | 144 | 2 |
| Sand & Gravel | ✓ | 144 | 156 | 12 |
| Sandy Clay | ✓ | 156 | 160 | 4 |

RECEIVED 97 JUL 28 PM 12:15 STATE ENGINEERS OFFICE

Date started July 12, 1997
Date completed July 15, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Air | 25+ | | 1½ |

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 5/8 Inches | 0 Feet | 50 Feet |
| 9 7/8 Inches | 50 Feet | 160 Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13 | .188 | +2 | 160 |

Perforations:
Type perforation Factory Cut
Size perforation 1/8 x 4 5 Row
From 140 feet to 160 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 110 feet to 160 feet

9. WATER LEVEL
Static water level 45' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc (Contractor)
Address 7780 Curry Rd (Contractor)
Fallon NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 11586
Signed [signature] By driller performing actual drilling on site or contractor
Date 7-24-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627