

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 68711
 Permit No. _____
 Basin 16a

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15569

1. OWNER Brady Winberry ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2611 E. Mickey 2611 E. Mickey
Pahrump, NV 89048

2. LOCATION NW 1/4 NE 1/4 Sec. 12 T 21 N/S R 53E E Nye County
 PERMIT NO. 44-521-21 N/A
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
		0		
BROWN CLAY		0	2	2
GREY POPCORN		3	6	3
BROWN CALACHE		6	10	4
GREY CALACHE		10	14	4
BROWN CALACHE		14	21	7
BROWN CLAY		21	32	11
LIGHT BROWN CLAY		32	40	8
BROWN CLAY /GRAVEL		40	48	8
LIGHT BROWN CLAY		48	57	9
BROWN CLAY		57	63	6
BROWN CLAY/GRAVEL		63	70	7
BROWN CLAY	X	70	81	11
LIGHT BROWN CLAY/GRAVEL	X	81	99	18
BROWN CLAY/GRAVEL	X	99	110	13
BROWN CLAY	X	110	120	10
LIGHT BROWN CLAY	X	120	132	12
BROWN CLAY	X	132	140	8

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 7/8 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation SAW CUT
 Size perforation .188
 From 100 feet to 140 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc.
 Contractor
 Address 2301 Winery Road, Suite 2
 Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2886
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 10.21.97

Date started 10/16/97 _____, 19____
 Date completed 10/16/97 _____, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>.5</u>	<u>na</u>	<u>.50</u>