

OFFICE USE ONLY
 Log No. 118772
 Permit No. _____
 Basin 128

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29393

1. OWNER Oxbow Geothermal Corp. ADDRESS AT WELL LOCATION Oxbow Power Plant
 MAILING ADDRESS 9790 Gateway Dr. Suite 220 Dixie Valley, NV
Reno, Nevada 89511

2. LOCATION SE $\frac{1}{4}$ SW $\frac{1}{4}$ Sec. 33 T. 25 N/S R. 37 E. Churchill County
 PERMIT NO. 49572 N/A Parcel No. N/A Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Test
 Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Alluvium		0	4818	4818
Tuff & Tuffaceous seds		4818	5991	1173
Miocene basalt		5991	7300	1309
Miocene Sediments		7300	8500	1200
Gabbro		8500	8900	400
Quartzite		8900	9136	236
Granite		9136	9270	134
	8900-			
	9200			

8. WELL CONSTRUCTION
 Depth Drilled 9270 Feet Depth Cased 8577 Feet

HOLE DIAMETER (BIT SIZE)
 From To
17 1/2 Inches 0 Feet 5230 Feet
12 1/4 Inches 5230 Feet 8587 Feet
8 1/2 Inches 8587 Feet 9270 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20"	94	.438	0	1336
13 3/8	72	.514	0	5165
9 5/8"	43.5, 47	.435, .472	4927	8577

Perforations:
 Type perforation None
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 0-8577
 Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started May 1 19 97
 Date completed June 30 19 97

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>1340</u>		<u>12</u>

9. WATER LEVEL
 Static water level ± 3000 feet below land surface
 Artesian flow 1340 G.P.M. 84 P.S.I.
 Water temperature 475 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Veco Drilling Company Contractor
 Address 3508 Standard St. Contractor
Bakersfield, CA 93308

Nevada contractor's license number issued by the State Contractor's Board #0021035
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller G 1899

Signed Charles M. Beigle
 By driller performing actual drilling on site or contractor
 Date 7-15-97

RECEIVED
 97 JUL 20 PM 2:15
 STATE GEOLOGICAL SURVEY

7-28-2002