WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68775
Permit No.
Basin 162

NOTICE OF INTENT NO. 15563

1. OWNER Jessie and Linda Bratton
MAILING ADDRESS 4660 E. Turner
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
4660 E. Turner

2. LOCATION SW 1/4 SE 1/4 Sec. 20 T 21 N/S R 54E E NYE County
PERMIT NO. _____ Issued by Water Resources
45-303-22 Parcel No.
Green Saddle Ranch Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY		0	2	2
GREY CLAY		2	6	4
BROWN CLAY/GRAVEL		6	10	4
BROWN CLAY/GRAVEL		10	22	12
BROWN CLAY		22	40	18
GRAVEL/BROWN CLAY		40	56	16
LIGHT BROWN CLAY		56	71	15
GREY CLAY		71	87	16
BROWN CLAY/GRAVEL		87	100	13
BROWN CLAY	X	100	118	18
BROWN CALACHE	X	118	132	14
BROWN CALACHE	X	132	140	8

OCT 31 1997

Date started 10/6/97 , 19__
Date completed 10/6/97 , 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
.5	na	.50

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 7/8	Inches	0 Feet	140 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
Type perforation SAW CUT
Size perforation .188
From 100 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed Larry Strickland By driller performing actual drilling on-site or contractor
Date 10-21-97