WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68778
Permit No.
Basin 724

NOTICE OF INTENT NO. 30383

1. OWNER Wholey Construction
MAILING ADDRESS P.O. Box 60412
Reno, NV 89506

ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ NW ¼ Sec. 13 T 21 N/S R 18 East Washoe County
PERMIT NO. (Issued by Water Resources) 086-260-07 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	5	5
Brown D.G.		5	20	15
Brown Sand		20	60	40
Brown sand with Brown Clay		60	120	60
Brown Clay with Multi colored sand Course		120	200	80
Multi color gravel	X	200	270	70
T.D. 270'				

Date started July 22, 1997
Date completed July 25, 1997

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 270 Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	50 Feet
8 1/2 Inches		50 Feet	270 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	+1½	270

Perforations:
Type perforation Factory Sawed
Size perforation 3/32 x 3
From 230 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 270 feet to 50 feet

9. WATER LEVEL
Static water level 200 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service, Inc. (Contractor)
Address P.O. BOx 60130 (Contractor)
Reno, NV 89506
Nevada contractor's license number issued by the State Contractor's Board 35387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
Signed Larry Welch (By driller performing actual drilling on site or contractor)
Date Aug 4, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627