

Well # 32-6

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 18779  
Permit No. \_\_\_\_\_  
Basin. 128

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32819

1. OWNER OYBOW LEATHERMAI CORP. ADDRESS AT WELL LOCATION North of Dixie Valley Power Plant  
MAILING ADDRESS 9790 GATEWAY DR SUITE 220  
RENO NEVADA 89511  
2. LOCATION NE 1/4 NW 1/4 Sec 26 T. 24 N/S R. 37 E Churchill County  
PERMIT NO. W-483162509 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GRAVEL WITH BEN CH MATERIALS		0	60	60
BRYN CLY		60	65	5
GRAVEL & CLY STRINGERS		65	140	75
BAIDERS & GRAVEL	X	140	200	60
GREEN CLY SOME GRAVEL		200	240	40
GRAY CLY		240	250	10
BAIDER WITH CLY STRINGERS		250	310	60
GRAVEL	Y	310	380	70
BEN CLY WITH SOME GRAVEL		380	400	20
WEATHERED WADRO BED ROCK	X	400	490	90
GREEN CLY		490	500	10

8. WELL CONSTRUCTION  
Depth Drilled 500 Feet Depth Cased 500 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
14 3/4 Inches 0 Feet 90 Feet  
8 3/4 Inches 90 Feet 500 Feet  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
9 5/8 43.50 .500 0 90  
6 7/8 12.9 .188 72 500

Perforations:  
Type perforation MILLED  
Size perforation 3 1/8  
From 340 feet to 360 feet  
From 380 feet to 500 feet  
Surface Seal:  Yes  No Seal Type:  Neat Cement  
Depth of Seal 90  Cement Grout  
Placement Method:  Pumped  Concrete Grout  
 Poured  
Gravel Packed:  Yes  No  
From 50 feet to 500 feet

9. WATER LEVEL  
Static water level 150 feet below land surface  
Artesian flow NO G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
Water temperature 90 °F Quality POOR

Date started 7-26 19 97  
Date completed 8-6 19 97

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>200</u>	<u>150</u>	<u>7 HRS</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name WOYTEK DRILLING CO INC Contractor  
Address 2220 STAME DR. Contractor  
RENO NEVADA 89511  
Nevada contractor's license number issued by the State Contractor's Board 024521A  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1442  
Signed Thomas M. Hlavik  
By driller performing actual drilling on site or contractor  
Date 8-6-97