WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68788
Permit No.
Basin 212

NOTICE OF INTENT NO. 13998

1. OWNER Clark County Regional Transportation Commission
MAILING ADDRESS 301 Clark Avenue
Las Vegas, Nevada

ADDRESS AT WELL LOCATION Approximately 150' West of Las Vegas Boulevard and 120' South of Stardust Drive

2. LOCATION SE ¼ SW ¼ Sec. 9 T. 21 N/S R. 61 E Clark County

PERMIT NO. M2163 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE: [ ] Domestic [ ] Irrigation [X] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE: [ ] Cable [X] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt & Fill		0	.5	.5
Silty Gravel		.5	2	1.5
Silty Sand		2	4	2
Silty Gravel		4	6	2
Silty Sand		6	8	2
Silty Gravel	19	8	19	11
Cemented Sand & Gravel	X	19	23	4
Sandy Clay	X	23	25	2
Caliche	X	25	42	17
Silty Gravel	X	42	43	1
Caliche	X	43	45	2
Silty Gravel	X	45	46	1
Caliche		46	47	1
Clayey Silty	X	47	49	2
Caliche		49	50	1
Silty Gravel	X	50	51	1
Caliche		51	53	2
Clayey Silt	X	53	57	4
Silty Clay	X	57	60	3

RECEIVED
AUG 03 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 6/18, 19 92
Date completed 6/18, 19 92

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

N/A	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased ~~50~~ 60 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
2 Inches		0 Feet	60 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2			0	50

Perforations:
Type perforation factory slotted
Size perforation 0.02"
From 50 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 60 feet

9. WATER LEVEL
Static water level 19 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Kleinfelder, Inc. (Contractor)
Address 6850 S. Paradise Road, Las Vegas, NV 89119 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1591

Signed Mark P. Dunlap (By driller performing actual drilling on site or contractor)
Date 7-29-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627