

OFFICE USE ONLY  
 Log No. 68799  
 Permit No. \_\_\_\_\_  
 Basin. 87

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34703  
950 So. Rock Blvd.  
SPARKS, NV 89502

1. OWNER WESTERN NEVADA SUPPLY CO ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 950 SO. ROCK BLVD. \_\_\_\_\_  
SPARKS, NV 89502 \_\_\_\_\_

2. LOCATION NE 1/4 SW 1/4 Sec. 8 T. 19 N/S R. 20 E WASHOE County \_\_\_\_\_  
 PERMIT NO. 1710 1035 Parcel No. 034-050-26 Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other HSA

6. LITHOLOGIC LOG

MW-1	Material	Water Strata	From	To	Thick-ness
	PULL COVER				
	RUN A ROD				
	BREAK BOTTOM END OFF OF PVC				
	PUMP CEMENT FROM BOTTOM TO GS				
	PULL ALL PVC				
	PUMP CEMENT TO GS				
	CONCRETE @ SURFACE				

8. WELL CONSTRUCTION

Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5		3/4 40	0	5

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 5 feet to 25 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 25  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 8-6, 1997  
 Date completed \_\_\_\_\_, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 7' 5" feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA DRILLING INC Contractor  
 Address 75 LEWERS CREEK RD Contractor  
CARSON CITY NV 89704  
 Nevada contractor's license number 13697A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1902  
 Division of Water Resources, the on-site driller  
 Signed John B. Deined  
 By driller performing actual drilling on site or contractor  
 Date 8-11-97