

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 68813  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28480

1. OWNER SILVEIRA CONSTRUCTION ADDRESS AT WELL LOCATION 1931 SHEEP CAMP  
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION NW 1/4 NE 1/4 Sec. 12 T. 12 N. R. 20 E. DOUGLAS County  
 PERMIT NO. 23-190-13 EAST VALLEY Subdivision Name

Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>PAVY loam</u>	<u>NO</u>	<u>0'</u>	<u>3'</u>	<u>3'</u>
<u>broken Rock, COBBLES &amp; GRAVEL</u>	<u>NO</u>	<u>3'</u>	<u>92'</u>	<u>89'</u>
<u>Brown clay &amp; some GRAVEL</u>	<u>NO</u>	<u>92'</u>	<u>110'</u>	<u>18'</u>
<u>HEAVY GRAVELS &amp; COBBLES</u>	<u>NO</u>	<u>110'</u>	<u>190'</u>	<u>80'</u>
<u>BRN. CLAY</u>	<u>NO</u>	<u>190'</u>	<u>205'</u>	<u>15'</u>
<u>GRAVEL</u>	<u>YES</u>	<u>205'</u>	<u>220'</u>	<u>15'</u>
<u>BRN. CLAY &amp; Broken Rock</u>	<u>NO</u>	<u>220'</u>	<u>230'</u>	<u>10'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 230 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 50 Feet  
9 7/8 Inches 50 Feet 230 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1</u>	<u>230</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 1/8 x 3  
 From 200 feet to 220 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 230 feet

9. WATER LEVEL  
 Static water level 95 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC Contractor  
 Address 879 RITTER DR. Contractor  
GARDNERVILLE, NV 89410  
 Nevada contractor's license number issued by the State Contractor's Board 27673A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1533  
 Signed Scott Chitwood  
 By driller performing actual drilling on site or contractor  
 Date 4-15-97

Date started 3/31, 1997  
 Date completed 4/14, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>25+</u>	<u>-</u>	<u>2</u>

RECEIVED  
 07 APR 16 AM 11:28  
 STATE ENGINEERS OFFICE