

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32035

1. OWNER ELKO CITY CORP. ADDRESS AT WELL LOCATION None  
 MAILING ADDRESS 1751 COLLEGE AVE.  
ELKO, NV 89801

2. LOCATION NW 1/4 SE 1/4 Sec. 30 T. 35 R. 56 E. ELKO County  
 PERMIT NO. 62095 T 06-32H-01-7 None Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	1	1
Sandy clay		1	21	20
Loose gravel	<u>✓</u>	20	25	5
Clay		25	55	30
Sand & gravel	<u>✓</u>	55	70	15
Clay		70	80	10
Alternating thin beds of clay & sand	<u>✓</u>	80	115	35
Clay		115	150	35
Alternating thin beds of clay, sand & gravel	<u>✓</u>	150	200	50
		T.D. 200		

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 201 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
12 Inches 0 Feet 50 Feet  
10 Inches 50 Feet 200 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>+1</u>	<u>200</u>

Perforations:  
 Type perforation Mill slots / torch cut  
 Size perforation 3/16 x 3" 1/8" x 5"

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 80 feet to 120 feet  
 From 140 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

Date started 5-17, 1996  
 Date completed 5-23, 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 11.5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Muth Drilling Co.  
203 Pine Street  
 Address Elko, NV 89801  
 Contractor

Nevada contractor's license number issued by the State Contractor's Board 10819  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632

Signed James V. Muth  
 By driller performing actual drilling on site or contractor  
 Date 5-25-96