WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68832
Permit No.
Basin 162

NOTICE OF INTENT NO. 15574

1. OWNER Cleo Byrd
MAILING ADDRESS 2390 E. Lewis
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
2390 E. Lewis

2. LOCATION NE 1/4 NW 1/4 Sec. 13 T 21 N/S R 53E E NYE County
PERMIT NO. _____ Issued by Water Resources | 44-591-04 Parcel No. | Conestoga Country Subdivision Name

**3. WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

**4. PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

**5. WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| BROWN CLAY | | 0 | 8 | 8 |
| GREY CALACHE | | 8 | 12 | 4 |
| BROWN CALACHE | | 12 | 17 | 5 |
| BROWN CLAY | | 17 | 34 | 17 |
| BROWN CLAY | | 34 | 52 | 18 |
| LIGHT GREY CLAY | | 52 | 65 | 13 |
| BROWN CLAY | X | 65 | 77 | 12 |
| BROWN CLAY | X | 77 | 91 | 14 |
| GREY CLAY | X | 91 | 110 | 19 |
| BROWN CLAY | X | 110 | 128 | 18 |
| LIGHT BROWN CLAY | X | 128 | 140 | 12 |

Date started 10/26/97, 19__
Date completed 10/26/97, 19__

**7. WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| .5 | na | .50 |

**8. WELL CONSTRUCTION**
Depth Drilled 140 Feet Depth Cased 140 Feet

**HOLE DIAMETER (BIT SIZE)**

| | | From | To |
|---|---|---|---|
| 12 7/8 | Inches | 0 Feet | 140 Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 3.7 | .280 | 0 | 140 |

**Perforations:**
Type perforation SAW CUT
Size perforation .188
From 100 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

**9. WATER LEVEL**
Static water level 65 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COOL °F Quality GOOD

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed Larry Strickland (By driller performing actual drilling on-site or contractor)

Date 10-27-97