WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68833
Permit No.
Basin 162

NOTICE OF INTENT NO. 15573

1. OWNER Strickland Construction Co.
MAILING ADDRESS 2301 Winery Rd.
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
3610 S. National

2. LOCATION NE 1/4 SE 1/4 Sec. 31 T 20 N/S R 54E E NYE County
PERMIT NO. _____ Issued by Water Resources | 41-161-13 Parcel No. | Calvada Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY BROWN LOAM		0	13	13
SANDY BROWN LOAM		13	28	15
BROWN CLAY		28	42	14
LIGHT BROWN CLAY		42	61	19
BROWN CLAY		61	79	18
BROWN CLAY		79	85	6
BROWN CLAY/GRAVEL	X	85	104	19
BROWN CLAY	X	104	110	6
BROWN CALACHE	X	110	119	9
BROWN CALACHE	X	119	134	15
BROWN CLAY	X	134	150	16

OCT 30 1997

Date started 10/25/97 , 19__
Date completed 10/25/97 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
.5	na	.50

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 7/8	Inches	0 Feet	140 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
Type perforation SAW CUT
Size perforation .188
From 110 feet to 150 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 83 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed Larry Strickland (By driller performing actual drilling on-site or contractor)
Date 10-22-97