WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 688668
Permit No.
Basin 212

NOTICE OF INTENT NO. 14413

1. OWNER ITT SHERATON
MAILING ADDRESS 3145 So. LAS VEGAS BLVD
LAS VEGAS NV 89109
ADDRESS AT WELL LOCATION 3145 So. LAS VEGAS BLVD

2. LOCATION SE ¼ SW ¼ Sec. 9 T 21 N/S R 61 E CLARK County
PERMIT NO. MO-2552 (Issued by Water Resources) 162-16-102-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-3
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/FILL		0	3	3
SILTY CLAY		3	9	6
CLAYEY GRAVEL		9	13	4
CMT SAND/GRAVEL		13	17	4
CLAYEY GRAVEL		17	23	6
CEMENTED SAND/GRAV		23	28	5
SILTY CLAY		28	31	3
CALICHE		31	33	2
CLAYEY GRAVEL		33	40	7

RECEIVED
MAR 23 1995
DIV. of Water Resources
Branch Office Las Vegas, NV

Date started MARCH 3, 1995
Date completed MARCH 3, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 39 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
8	0	40

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	1.9	0.237	0	39

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 9 feet to 39 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-5'/5-7' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 7 feet to 40 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DONALD WILSON
Address 4670 So POLARIS AVE (Contractor)
LAS VEGAS NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3-20-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627