WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68869
Permit No.
Basin 212

NOTICE OF INTENT NO. 14413

1. OWNER ITT SHERATON
MAILING ADDRESS 3145 SO LAS VEGAS BLVD LAS VEGAS NV 89109
ADDRESS AT WELL LOCATION 3145 SO. LAS VEGAS BLVD.

2. LOCATION SE ¼ SW ¼ Sec. 9 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. MO-2552 (Issued by Water Resources) 162-16-102-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE PW-4
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/FILL		0	4	4
SILTY CLAY		4	12	8
CEMENTED SAND/GRAVEL		12	19	7
CLAYEY GRAVEL		19	21	2
CEMENTED SAND/GRAVEL		21	25	4
CALICHE		25	28	3
CLAYEY GRAVEL		28	31	3
CEMENTED SAND + GRAVEL		31	35	4
CLAYEY GRAVEL		35	40	5

RECEIVED
MAR 23 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started MARCH 3, 19 95
Date completed MARCH 3, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 38 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
8	0	40

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	1.9	0.237	0	38

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 13 feet to 38 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-8'/8-11' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 11 feet to 40 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DONALD WILSON
Contractor
Address 4670 SO. POLARIS AVE
Contractor
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed
By driller performing actual drilling on site or contractor
Date 3-20-95

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627