

Well #4

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 68900  
Permit No. 212  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 9726

1. OWNER Humana Hospital ADDRESS AT WELL LOCATION Humana Hospital  
MAILING ADDRESS MG Fauci 3186 S. Maryland Pkwy  
4320 W. D.I. Ste. C  
2. LOCATION NW 1/4 SW 1/4 Sec 11 T 21 N/S R 61 E ca clark County  
PERMIT NO. DW-1009 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other dewater  
4. PROPOSED USE  
 dewatering  Domestic  
 Municipal/Industrial  Irrigation  Test  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
type 2		0	3	3
calichi		3	4	1
brown clay & gravel		4	8	4
white clay & gravel		8	17	9
cemented congl.		17	28	6
brown silty clay		28	38	10

8. WELL CONSTRUCTION  
Depth Drilled 38 Feet Depth Cased 38 Feet  
HOLE DIAMETER (BIT SIZE)  
From 24 Inches To 38 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>14</u>	<u>36.71</u>	<u>.250</u>	<u>+1</u>	<u>38</u>

Perforations:  
Type perforation mill cut  
Size perforation 1/4 x 6  
From 18 feet to 38 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
Depth of Seal \_\_\_\_\_  Cement Grout  
Placement Method:  Pumped  Concrete Grout  
 Poured  
Gravel Packed:  Yes  No  
From 0 feet to 38 feet

RECEIVED  
FEB 18 1993  
Div. of Water Resources  
Branch Office - Las Vegas, NV

9. WATER LEVEL  
Static water level 8 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 2-4 1993  
Date completed 2-4 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Allen Drilling, Inc. Contractor  
Address 4847 S. Valley View Contractor  
Las Vegas, Nev. 89103  
Nevada contractor's license number issued by the State Contractor's Board 0018916 0018917  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661  
Signed Donald Wall  
By driller performing actual drilling on site or contractor  
Date 2-11-93