

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. **68903**
Permit **112**
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. **14420**

801 W. Colton Ave

1. OWNER **Broadbent & Assoc**
MAILING ADDRESS **833 NV Hwy 614**
BC, NV 89005

ADDRESS AT WELL LOCATION **North Las Vegas NV**

2. LOCATION **SE 1/4 SW 1/4 Sec 11 T 20 N R 61 E** Clark County

PERMIT NO. **MO-24328** Parcel No. **139-11-402-001**

Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. Domestic Municipal/Industrial
 Irrigation Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other **Auger**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty sand, Gravel		0'	10'	10'
Sand silt Clay		10'	20'	10'
Silty clay		20'	35'	15'
Silty clay w/gravel		35'	45'	10'
caliche water		46'	47'	1'
Silty Clay		47'	69'	

8. WELL CONSTRUCTION
Depth Drilled **0** Feet
WELL CONSTRUCTION **69'** Feet
HOLE DIAMETER (BIT SIZE)
Inches **8"** From **69'** To **69'** Feet
Inches **69'** Feet **69'** Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.69	0.218	49	69'

Perforations:
Type perforation **Factory slot**
Size perforation **0.020**
From **49** feet to **69** feet
From **69** feet to **69** feet
From **69** feet to **69** feet
From **69** feet to **69** feet

Surface Seal: Yes No Seal Type:
Depth of Seal **0' to 45/45-47'** Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From **47** feet to **69** feet

9. WATER LEVEL
Static water level **52.55** feet below land surface
Artesian flow **0** G.P.M. P.S.I.
Water temperature **9** °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Thomas R. High**
Address **4670 So. Polaris Ave**
LV NV 89103
Contractor
Nevada contractor's license number **89103**
Issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **M-1869**

Signed **Thomas R. High**
Date **April 17th 1995**
By driller, performing actual drilling on site of contractor

Date started **April 3 1995**
Date completed **April 3 1995**

7. WELL TEST DATA
TEST METHOD: Bailor Pump Air Lift
 Draw Down (Feet Below Static) Time (Hours)

TEST METHOD:	Bailor	Pump	Air Lift
G.P.M.			
(Feet Below Static)			
Time (Hours)			