

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13765

1. OWNER Southland Corp. c/o SECOR ADDRESS AT WELL LOCATION 3275 So. Eastern Ave Las Vegas
 MAILING ADDRESS 3021 S. Valley View St. E 104, LV. 89102
 2. LOCATION SE 1/4 SE 1/4 Sec. 11 T 21 N 61 E Clark County
 PERMIT NO. MO-2492 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Poorly Graded sand and Gravel		0'	1.5'	
Sandy silt with trace of clay		1.5'	5'	
Caliche		5'	6'	
Sand with silt.		6'	10'	
Clay dark greenish silt with clay		10'	15'	
Poorly Graded sand		15'	20'	
		20'	25'	

8. WELL CONSTRUCTION
 Depth Drilled 25' Feet Depth Cased 25' Feet
 HOLE DIAMETER (BIT SIZE)
 From 8" Inches To 25' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.64</u>	<u>0.154</u>	<u>0'</u>	<u>25'</u>

Perforations:
 Type perforation Factory slot
 Size perforation 0.20
 From 20' feet to 25' feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 11/14, 1994
 Date completed 11/14, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 JAN 04 1995
 Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Thomas High Contractor
 Address 4670 So. Polaris Ave Las Vegas NV. 89103 Contractor
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 12-3-95