WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

In Book

OFFICE USE ONLY
Log No. 68907
Permit No.
Basin 212
PW-3

NOTICE OF INTENT NO. 10583

1. OWNER Pat Clark
MAILING ADDRESS 2575 E. SAHARA AVE
LAS VEGAS NV 89121

ADDRESS AT WELL LOCATION Pat Clark Pontiac
2575 E. SAHARA AVE
LAS VEGAS NV 89121

2. LOCATION NW ¼ NW ¼ Sec. 12 T. 21 N/S R. 61 E. Clark County

PERMIT NO. MO-2178 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT - Fill		0	3.5	3.5
Clayey Silt w/sand		3.5	8.0	4.5
Silty clay		8.0	13	5.0
Clay w/silt		13	23	10.0
Silt w/clay		23	32	9.0
Silty clay		32	35	3.0
T.D. = 35'				

Date started July 30, 19 92
Date completed July 30, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
AUG 13 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10'	0	35'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	21bs	SCH. 40	0	35

Perforations:
Type perforation Factory slotted
Size perforation 0.020
From 5 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 3.5 feet to 35 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Richard LeBlanc / Converse Consultants (Contractor)
Address 4670 S. Polaris Ave (Contractor)
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817
Signed (By driller performing actual drilling on site or contractor)
Date 8-13-92

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627