WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY.
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

in Book

OFFICE USE ONLY
Log No. 68909
Permit No.
Basin 212

FW-1

NOTICE OF INTENT NO. 10581

1. OWNER PAT CLARK
MAILING ADDRESS 2575 E. SAHARA
LAS VEGAS NEV 89121

ADDRESS AT WELL LOCATION PAT CLARK PONTIAC
2575 E. SAHARA
LAS VEGAS NV 89121

2. LOCATION NW ¼ NW ¼ Sec. 12 T. 21 N/S R. 61 E. CLARK County

PERMIT NO. MO-2178 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT - Fill		0	3	3.0
Silty Sand w/clay		3	8	5.0
Silty Clay		8	14	6.0
Clay w/silt		14	18	4.0
Clay w/silt (wet)		18	23	5.0
Sandy silt w/clay		23	33	10.0
Silty clay w/gravels		33	40	7.0

J.D = 40'

Date started July 28, 1992
Date completed July 28, 1992

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
AUG 13 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10" Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	2 lbs	SCH. 40	0	40

Perforations:
Type perforation Factory slotted
Size perforation 0.020
From 5 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3'
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 3 feet to 40 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Richard LeBlanc / Convers Consultants
Contractor

Address 4670 S. Polaris AVE
Contractor
LAS VEGAS NV 89103

Nevada contractor's license number issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1817

Signed Dr. R. LeBlanc
By driller performing actual drilling on site or contractor

Date 8.13.92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627