WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68940
Permit No.
Basin

NOTICE OF INTENT NO. 38317

1. OWNER: JOHN ADELMAN
MAILING ADDRESS: 17605 Northridge Ave., Reno, Nevada 89506
ADDRESS AT WELL LOCATION: 17505 Northridge Ave., Reno, Nevada 89506

2. LOCATION: SE ¼ SW ¼ Sec 29 T 21N N/S R 18 E Washoe County
PERMIT NO. (Issued by Water Resources) | Parcel No. 081-192-12 | Subdivision Name: Cold Springs

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	11	10
Weathered granite		11	14	3
Brown sandy clay		14	61	47
Brown coarse sands		61	63	2
Brown sandy clay		63	78	15
Soft zone (app 4 GPM)	X	78	81	3
Brown sandy clay		81	101	20
Gray sandy clay		101	105	4
Brown sandy clay		105	131	26
Coarse gravels & sand	X	131	139	8
Gray clay		139	145	6

Date started 8-5-97, 19
Date completed 8-5-97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		

8. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	145 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	145

Perforations:
Type perforation: factory sawed slot
Size perforation: 3/32 x 3 x 5 around
From 80 feet to 100 feet
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal: 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 145 feet

9. WATER LEVEL
Static water level 41 feet below land surface
Artesian flow G.P.M. 15 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): WAYNE DRILLING, INC.
Address (Contractor): P.O. BOX 12370, RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board: 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 923
Signed: Gary L. Wellman (By driller performing actual drilling on site or contractor)
Date: August 7, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627