WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68943
Permit No.
Basin 92B

NOTICE OF INTENT NO. 38308

1. OWNER LEONA GALAU
MAILING ADDRESS 11585 Overland Road
Reno, Nevada 89506

ADDRESS AT WELL LOCATION Same

2. LOCATION SW ¼ NE ¼ Sec. 15 T 21N N/S R 19 E Washoe County
PERMIT NO. Issued by Water Resources 080-395-04 Parcel No. Lemmon Valley Subdivision Name

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE No Mud
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Decomposed granite sands with clay		1	16	15
Brown sand		16	19	3
Decomposed granite sands w/mixed clay		19	44	25
Soft zone		44	47	3
Brown sandy clay		47	138	91
Brown fine sand	X	138	155	17
Green granite		155	193	38
Soft zone (rusty)		193	194	1
Green granite		194	227	33
Fracture	X	227	228	1
Green granite		228	242	14
Fracture	X	242	267	25
Green granite		267	280	13
Fracture	X	280	281	1
Green granite		281	300	9

Date started 7-30-97, 19
Date completed 7-31-97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	225 Feet
6 1/8 Inches		225 Feet	300 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	225
5		.188	214	300
To stop sand in upper stratas				

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 220 feet to 240 feet
From 260 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 225 feet

9. WATER LEVEL
Static water level 134 feet below land surface
Artesian flow G.P.M. 15 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. Contractor
Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] By driller performing actual drilling on site or contractor
Date Augusr 4, 1997

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

8-20-97 Received 8-29-97

(O)-627