

OFFICE USE ONLY
 Log No. 8998
 Permit No. _____
 Basin 87

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21864

1. Consultant: HARDING LAWSON ASSOCIATES Client: _____
 OWNER: _____ ADDRESS AT WELL LOCATION: NDOT
 MAILING ADDRESS: 961 Matley Lane, Suite 110
Reno, Nevada 89502
Nugget Avenue
Sparks, Nevada
 2. LOCATION: NE 1/4 NE 1/4 Sec. 8 T 19N N/S R 20 E Washoe County
 PERMIT NO. 12-816 WELL #1 032-220-71 Pyramid & I-80 Interchange
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
MONITOR WELL #1				
Static water level @15.75 feet				
Total depth @34.1 ft.				
Install tremie pipe to bottom				
Mix & pressure pump neat cement to fill casing to top				
3 sacks cement used				
Break out concrete and remove traffic cover				
Equipment used:				
Tremie pipe				
Cement pump				
Materials used:				
3 sacks Portlan Cement Type II				
Location:				
9.4 feet N of Rail Road Track				
131.2 feet E of Rail Road Switch				

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

From		To	
_____ Inches	_____ Feet	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation _____
 Size perforation _____

From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured
 Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 7-31-97, 19____
 Date completed 7-31-97, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level: _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370
RENO, NEVADA 89510 Contractor

Nevada contractor's license number 0022549
 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date August 4, 1997