WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 68980
Permit No.
Basin 212

NOTICE OF INTENT NO. 16872

1. OWNER WELLS FARGO BANK
MAILING ADDRESS 3800 HOWARD HUGHES PKWY
LAS VEGAS, NV 89109

ADDRESS AT WELL LOCATION 840 N DECATUR BLVD LAS VEGAS NV 89107

2. LOCATION NW ¼ SW ¼ Sec 30 T 20 N/S R 61 E CLARK County
PERMIT NO. Issued by Water Resources | 139-30-301-002 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	0.3	0.3
FILL		0.3	1.0	0.7
SILT, BROWNISH YELLOW		1	4.5	3.5
~~SET~~ GRAVELLY SILT		4.5	11.5	7
LIGHT GRAY				
CLAY VERY PALE BROWN	▽	11.5	19	7.5
CALICHE		19	21	2
CLAY WHITE		21	24	3
CALICHE		24	25	1
CLAY WHITE				

Date started 10/27/97, 19
Date completed 10/27/97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 31 Feet Depth Cased 30.4 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	31 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	0.70	0.31	0	30.4

Perforations:
Type perforation FACTORY MACHINE SLOTTED
Size perforation 0.010-INCH
From 15.3 feet to 29.8 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-9
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 12 feet to 31 feet

9. WATER LEVEL
Static water level 17.59 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WESTERN TECHNOLOGIES, INC. (Contractor)
Address 3611 W TOMPKINS AVE (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board:
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1761
Signed (By driller performing actual drilling on site or contractor)
Date 11/10/97

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627