WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

in Book

OFFICE USE ONLY
Log No. 68987
Permit No.
Basin 212

NOTICE OF INTENT NO. 11013

1. OWNER Nevada Power Company
MAILING ADDRESS P.O. box 230
Las Vegas, Nevada 89151

ADDRESS AT WELL LOCATION Clark Station
5640 S. Stephanie Street
Las Vegas, Nevada 89122

2. LOCATION SE ¼ SE ¼ Sec. 28 T 21 ~~N~~/S R 62 E Clark County
PERMIT NO. MO-2173 (Issued by Water Resources) Parcel No. Clark Station (Subdivision Name)

3. MW-5-92 WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Gravels		0	0.5	0.5
Gravelly Silt		0.5	5	4.5
Sandy Clay		5	8.5	3.5
Sand		8.5	9	0.5
Sandy Clay		9	13.5	4.5
Silty Sand	X	13.5	15	1.5
Red-brown Clay	X	15	25	10

RECEIVED
JUL 24 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started July 8, 1992
Date completed July 10, 1992

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 26.5 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	25 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	Sch. 40		0	25

Perforations:
Type perforation factory slotted
Size perforation 0.020
From 4.5 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 2 feet
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 3.5 feet to 25 feet

9. WATER LEVEL
Static water level 10.3 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality non-potable

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Kleinfelder, Inc./Mark Ducharme (Contractor)
Address 6850 S. Paradise Road (Contractor)
Las Vegas, Nevada 89119
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1591
Signed Mark Ducharme (By driller performing actual drilling on site or contractor)
Date 7-24-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627