

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 69082
 Permit No. 212
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11972

1. OWNER Western Summit ADDRESS AT WELL LOCATION 200 Athens Henderson NV
 MAILING ADDRESS 5470 Valley Highway Denver CO.
 2. LOCATION SF 1/4 Sec 36 T 21 N R 62 E County Clark
 PERMIT NO. DW 1007 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other BURAU

6. Clarifier LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SAND w/ GRAVEL</u>	<u>Gravel</u>	<u>0</u>	<u>20</u>	<u>20</u>
<u>GRAVEL w/ SAND</u>		<u>20</u>	<u>25</u>	<u>5</u>
<u>SANDY CLAY w/ GRAVEL</u>		<u>25</u>	<u>40</u>	<u>15</u>
<u>WHITE CLAY</u>		<u>40</u>	<u>50</u>	<u>10</u>

8. WELL CONSTRUCTION
 Depth Drilled 50 Feet Depth Cased 50 Feet
 HOLE DIAMETER (BIT SIZE)
 From 24 Inches To 50 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12</u>			<u>0</u>	<u>50</u>

Perforations:
 Type perforation SAW CUT
 Size perforation .040
 From 20 feet to 50 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to 50 feet

RECEIVED
 MAY 26 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 5-20, 1993
 Date completed 5-26, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Foot Hills Eng. Contractor
 Address 905 E 3rd St Corona Cal. Contractor
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1567
 Signed Clayton Sewell
 By driller performing actual drilling on site or contractor
 Date 5-20